

## OPTIONAL ACCESSORIES - ORDER SEPARATELY

Compressor Low Ambient Cut-Off	45F08	.	.	.	.
Compressor Sound Cover	18J42	.	.	.	.
Freezestat	3/8 in. tubing	93G35	.	.	.
	5/8 in. tubing	50A93	.	.	.
Indoor Blower Off Delay Relay	58M81	.	.	.	.
<sup>5</sup> Low Ambient Kit (30°F)	54M89	.	.	.	.
<sup>5</sup> Low Ambient Control (0°F)	Speed Control	X5867	.	.	.
	Weatherproof Kit	56N41	.	.	.
Mild Weather Kit	11B97	.	.	.	.
Monitor Kit - Service Light	76F53	.	.	.	.
Outdoor Thermostat Kit	Thermostat	10Z23	.	.	.
	Mounting Box	31461	.	.	.
Refrigerant Line Sets	L15-65-30, L15-65-40, L15-65-50		.	.	.
	Field Fabricate				.
Snow Guard	94M98	.	.	.	.
Unit Stand-Off Kit	94J45	.	.	.	.

NOTE - Extremes of operating range are plus 10% and minus 5% of line voltage.

<sup>1</sup> Sound Rating Number rated in accordance with test conditions included in AHRI Standard 270.

<sup>2</sup> Refrigerant charge sufficient for 15 ft. length of refrigerant lines. For longer line set requirements see the Installation Instructions for information about line set length and additional refrigerant charge required.

<sup>3</sup> HACR type circuit breaker or fuse.

<sup>4</sup> Refer to National or Canadian Electrical Code manual to determine wire, fuse and disconnect size requirements.

<sup>5</sup> Freezestat are recommended with Low Ambient Kit.



Visit us at [www.marsdelivers.com](http://www.marsdelivers.com)

Contact us at 517-787-2100

NOTE - Due to Allied Commercial ongoing commitment to quality, Specifications, Ratings and Dimensions subject to change without notice and without incurring liability. Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury. Installation and service must be performed by a qualified installer and servicing agency.

