

ENERGYGUIDE


Heat Pump
Cooling and Heating
Split System

HEAT CONTROLLER
JACKSON, MI
Model: A-VHP33SA-1



Cooling Efficiency Rating (SEER2)**

16.50-19.50



Range of Similar Models

** Seasonal Energy Efficiency Ratio 2

▼▼ This system's efficiency ratings depend on the coil your contractor installs with this unit. The heating efficiency rating varies slightly in different geographic regions. Ask your contractor for details.

Heating Efficiency Rating (HSPF2)**

10.00-10.50



Range of Similar Models

** Heating Seasonal Performance Factor 2

For energy cost info, visit
productinfo.energy.gov

Canada

ENERG GUIDE

Seasonal Energy Efficiency Ratio (SEER)
Air source heat pump

THIS MODEL A-VHP33SA-1

16.50-19.50

14.0 — *Uses least energy* → 42.0